

# Preliminary Assessment Report Project 6353894, 1901 SW GENESEE ST

Assessment Completed: 3/5/2013

**Project Description:** Add premanufactured single portable classroom building.

**Primary Applicant:** Samuel Cameron

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

# **Next Steps**

- 1. Review the requirements in this report and contact the staff members listed below with questions.
- 2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See <a href="SDOT Client Assistance Memo 2213">SDOT Client Assistance Memo 2213</a> for guidance about the 60% complete approval process.
- 3. Schedule an appointment for permit application intake with DPD. Please bring a copy of this report to your intake appointment.

#### **Questions About This Report**

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### **DPD Drainage Requirements**

Michelle M Macias, (206) 684-3068, michelle.macias@seattle.gov

#### **DPD Land Use Requirements**

Lori L Swallow, (206) 684-5627, Lori.Swallow@Seattle.Gov

#### **DPD Preapplication Site Visit Requirements**

Roger E Moore, (206) 733-9039, Roger.Moore@seattle.gov

#### **Seattle City Light Requirements**

Maneet Jain, (206) 684-3396

# **Seattle Department of Transportation Requirements**

Leo Kaarrekoski, leo.kaarrekoski@seattle.com

#### Seattle Public Utilities Requirements

Susie Larson, susie.larson@seattle.gov

## **Water Availability**

K Younge, (206) 684-5975, Karen. Younge@Seattle. Gov

#### **Other Resources**

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- Overview of the permit application process: <u>5 Steps for a Successful DPD Application Submittal</u>.
- User-friendly guides to city permitting processes: DPD and SDOT Client Assistance Memos.
- Detailed zoning information.
- <u>DPD's Checklists & Standards</u>, designed to help you make sure your permit application is complete and ready for review.

# Requirements

# **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

# **Existing Public Drainage Infrastructure**

Combined sewer main location: 19th Ave SW Combined sewer main size: 10-inch diameter

### Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Combined sewer.

# **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge (DPD DR 4-2011) is located at the following: Combined system.

# **DPD Land Use Code Requirements**

## **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (http://www.seattle.gov/transportation/rowimanual/manual/). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

#### 21ST AVE SW

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

#### **SW GENESEE ST**

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

# **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

1) Contours labels.

#### **ECA Mapping Unit and Type**

This project site appears to include the following ECAs and/or buffers:

Steep slope Wetland

# **Potential Impacts to Seattle Parks Property**

Park within 100 LF

#### **Tree Protection**

Existing trees appear to be shown accurately on the site plan

#### **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (<u>DR 16-2009</u>, Volume 2).

#### Show the following on the CSC/Post Construction Soil Amendment Plan:

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at http://web1.seattle.gov/DPD/InspectionRequest/default.aspx.

### **Inspectors Notes**

Because this is a temporary structure, submittal requirements for projects located on sites with ECA's may be waived. Discuss this option with the Permit Intake Specialist.

#### Standard Submittal Requirements for Projects in an ECA

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see <u>25.09.330A</u>)

Delineate the steep slope critical area on a site plan based on the survey (per SMC 25.09.020 A3b(5)). Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

The site appears to have areas with wetland vegetation and/or seasonal or permanent saturation. The permit application should be routed to a DPD wetland specialist for further review.

Submit a Wetland Site Assessment Report prepared by a qualified wetlands professional that evaluates and identifies wetlands within 100 feet of the subject property line for development proposed within 100 feet of a wetland (see SMC <u>25.09.160</u>).

Prepare a wetland delineation report per <u>Director's Rule 19-2006</u>, <u>Requirements for Wetland Site Assessment</u> Reports.

# **Seattle City Light Requirements**

## Street/Alley Requirements SW GENESEE ST

Other requirements: The existing parent parcel is considered one site. The electrical service to the new buildings will need to be consolidated from one service strike from SCL's distribution system. Per SCL Requirements for Electric Service Connection, http://www.seattle.gov/light/contractors/resc/, Chapter 5, page 28: "Single Service Rule", Seattle City Light will provide only one service to a site or building. Additional services will be supplied only at SCL's option and will be agreed to in writing. Please contact your Electrical Service Representative well in advance of construction for clarification and electrical service advice.

#### **Easements**

SCL power easement may be required. Property survey may be required at project's expense.

SCL blanket power easement over the entire parent parcel may be required. Property survey may be required at project's expense.

#### **Notes to Applicant**

For new service, an Application for Electrical Service must be submitted to Seattle City Light. Please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. The

Electrical Service Representative should also be contacted to coordinate electrical details for temporary power during construction. Your Electrical Service Representative is: Thomas Gravell, 206-386-1672, thomas.gravell@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

# **SDOT Requirements**

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

# **SPU Requirements**

## **Water Availability**

Your water availability assessment is in progress. If the assessment results in water system improvements, you will be required to follow SDOT's Street Improvement Permit Process (see <u>CAM 2211</u> and <u>CAM 2213</u>).

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at: <a href="http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos">http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos</a> 004542.pdf. For

questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seatte.gov.

**Other Requirements** 

# Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD CAM 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark of if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to CAM 208 for information regarding the application requirements for a SEPA review and CAM 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, <a href="Michale-Crooks@seattle.gov">Michale-Crooks@seattle.gov</a>, or visit the <a href="Licensing and Tax Administration Division website">Licensing and Tax Administration Division website</a>.